

Radon Testing Results

SOESD Klamath Falls Office

2685 Foothills Blvd.

Klamath Falls, OR 97603

and

SOESD Grants Pass Regional Office

409 N.W. 3rd

Grants Pass, OR 97526

Test results received March 4, 2019

On the following page are the Radon test results for the SOESD Klamath Falls Office and Grants Pass Regional office facilities.

Samples tested provided results below the 4.0 pCi/L level threshold. Oregon Revised Statute 332.166-167 requires school districts and education service districts to test again every ten years. However, the SOESD Healthy and Safe Schools Plan has established a minimum cycle of testing every five years.

If there are questions on the test results please contact Daniel Weaver, Business Manager, Southern Oregon ESD at 541-776-8580 or by e-mail at daniel_weaver@soesd.k12.or.us.

I5380 / JIM DEROUEN

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
7199305	2019-02-11	10:00 am	2019-02-14	10:00 am	71	KLAMATH	OFFICE	9	SOESD KLA	1	0.8
7199306	2019-02-11	10:00 am	2019-02-14	10:00 am	71	KLAMATH	OFFICE	4	SOESD KLA	1	< 0.3
7199308	2019-02-11	10:00 am	2019-02-14	10:00 am	71	KLAMATH	OFFICE	1	SOESD KLA	1	0.8
7199316	2019-02-11	10:00 am	2019-02-14	9:00 am	70	REGIONAL	OFFICE	COPY RM	SOESD REG	1	1.2
7199317	2019-02-11	10:00 am	2019-02-14	9:00 am	70	REGIONAL	OFFICE	SW OFFICE	SOESD REG	1	0.7
7199318	2019-02-11	10:00 am	2019-02-14	9:00 am	70	REGIONAL	OFFICE	EAST OFFICE	SOESD REG	1	0.8
7199321	2019-02-11	10:00 am	2019-02-14	10:00 am	71	KLAMATH	OFFICE	3	SOESD KLA	1	0.9
7199322	2019-02-11	10:00 am	2019-02-14	10:00 am	71	KLAMATH	OFFICE	6	SOESD KLA	1	1.1
7199324	2019-02-11	10:00 am	2019-02-14	11:00 am	71	KLAMATH	OFFICE	12	SOESD KLA	1	< 0.3
7199360	2019-02-11	10:00 am	2019-02-14	9:00 am	70	REGIONAL	OFFICE	SW OFFICE	SOESD REG	1	70.2
7199363	2019-02-11	10:00 am	2019-02-14	9:00 am	70	REGIONAL	OFFICE	KITCHEN	SOESD REG	1	< 0.3
7199365	2019-02-11	10:00 am	2019-02-14	9:00 am	70	REGIONAL	OFFICE	NW OFFICE	SOESD REG	1	< 0.3
7199367	2019-02-11	10:00 am	2019-02-14	11:00 am	71	KLAMATH	OFFICE	13	SOESD KLA	1	64.5
7199368	2019-02-11	10:00 am	2019-02-14	10:00 am	71	KLAMATH	OFFICE	5	SOESD KLA	1	0.8
7199370	2019-02-11	10:00 am	2019-02-14	10:00 am	71	KLAMATH	OFFICE	7	SOESD KLA	1	0.6
7199374	2019-02-11	10:00 am	2019-02-14	10:00 am	71	KLAMATH	OFFICE	10	SOESD KLA	1	1.0
7199375	2019-02-11	10:00 am	2019-02-14	9:00 am	70	REGIONAL	OFFICE	NW OFFICE	SOED REG	1	0.9
7199376	2019-02-11	10:00 am	2019-02-14	10:00 am	71	KLAMATH	OFFICE	2	SOESD KLA	1	0.8
7199377	2019-02-11	10:00 am	2019-02-14	10:00 am	71	KLAMATH	OFFICE	11	SOESD KLA	1	< 0.3
7199378	2019-02-11	10:00 am	2019-02-14	10:00 am	71	KLAMATH	OFFICE	6	SOESD KLA	1	1.1
7199379	2019-02-11	10:00 am	2019-02-14	10:00 am	71	KLAMATH	OFFICE	8	SOESD KLA	1	< 0.3
7823974	2019-02-11	10:00 am	2019-02-14	9:00 am	70	REGIONAL	OFFICE	KITCHEN	SOESD REG	1	0.8